Model-based predictive maintenance in building automation systems with user discomfort

Nathalie Cauchi^a, Karel Macek^b, Alessandro Abate^a

^a*Department of Computer Science, University of Oxford, Oxford, United Kingdom*

^b*Honeywell Prague Laboratory, Honeywell, s.r.o Prague, Czech Republic*

Abstract

This work presents a new methodology for quantifying the discomfort caused by non-optimal temperature regulation, in a building automation system, as a result of degraded biomass boiler operation. This discomfort is incorporated in a model-based dynamic programming algorithm that computes the optimal maintenance action for cleaning or replacing the boiler. A non-linear cleaning model is used to represent the different cleaning strategies under taken by contractors. The maintenance strategy minimizes the total operational costs of the boiler, the cleaning costs and the newly defined discomfort costs, over a long-term prediction horizon that captures the short-term daily thermal comfort within the heating zone. The approach has been developed based on real data obtained from a biomass boiler at a Spanish school and the resulting optimal maintenance strategies are shown to have the potential of significant energy and cost savings.

Keywords: Predictive maintenance, Biomass boiler modelling, Temperature regulation, Thermal comfort, Dynamic programming, Energy savings

1. Background & motivation

The European Union aims to increase the contribution of renewable energy sources by up to 20% by 2020 [1] and it is stipulated that biomass fuels will account for 56% of renewable energy generation [2]. Many research initiatives are being carried out to take advantage of biomass potential as a renewable energy source [3]. Biomass boilers provide a cleaner alternative to conventional gas boiler. However, this comes at a cost of being more subject to soot accumulation due to *fouling*. Heat transfer surface fouling is a continuous issue that negatively impacts heat exchanger operation by reducing the boiler efficiency and increasing the cost of operation [4]. Thus, optimal cleaning strategies are required to minimise the effect of fouling. This can be achieved by employing predictive maintenance strategies.

Predictive maintenance is defined as maintenance strategy that is able to forecast the trend of performance degradation [5]. The work in [6] addressed this issue by applying mathematical modelling to deduce the optimal maintenance policy that incorporates periodic inspection and replacements. A reliability-centred predictive maintenance policy for a continuously monitored system subject to degradation due to imperfect maintenance is proposed in [7]. In the context of heating devices for building automation systems (BAS), [8] devised an algorithm that optimises the frequency of the cleaning process, in order to improve boiler performance. Similarly, the work in [9] has applied more accurate first-principle modelling and optimised the duration and timing of the cleaning process. [10] suggested the synthesis of predictive maintenance strategies based on dynamic programming: this technique is further expanded by including a combination of forecasting and optimisation methods in [11]. Predictive maintenance of devices has been widely studied towards potential energy saving goals in BAS, however the effect of discomfort on occupants and its related costs has been broadly ignored [12, 13, 14]. Numerous contributions highlighting the effect of discomfort [15, 16] have stressed the importance of accounting for the cost of indoor thermal comfort.

This contribution studies the problem of quantifying discomfort due to non-optimal temperature regulation, in BAS, as a consequence of degraded boiler operation, and that of using this cost within a predictive

25 maintenance optimisation problem. Predictive maintenance strategies are computed based on a total costs
 26 including contributions due to operation, maintenance, and (new in this work) discomfort. Optimal strate-
 27 gies are computed using Dynamic Programming (DP) and comprise three alternative maintenance actions
 28 (No Action, Clean, and Replace). Unlike related studies in literature [11] focusing on long-term horizons
 29 (and weekly time steps), in order to account for discomfort this study needs to consider also daily horizons
 30 and intra-day temperature dynamics: we put forward a daily discomfort metric that can be embedded in the
 31 overall longer-term contributions to the cost function. A daily time step further allows for capturing trends
 32 that represent the output power consumed by the building. This leads to devising predictive maintenance
 33 strategies over larger horizons (for instance over 5 years) that newly account also for discomfort costs.

34 This article has the following structure: Section 2 introduces an approach for quantifying discomfort,
 35 which is followed by the synthesis of optimal maintenance policies in Section 3. This includes the embedding
 36 of discomfort metric within the policy synthesis architecture. The framework is applied to a Spanish school
 37 case study which is presented in Section 4. The resulting algorithms are demonstrated under different
 38 scenarios in Section 5, which also discusses the total energy and discomfort savings obtained by the scheme.

39 2. Discomfort as a consequence of degraded temperature control

40 In this study, we consider a correctly sized biomass boiler with a hopper, supplying thermal energy to
 41 a zone. The boiler has a fixed schedule and is turned on during the start of the working day and switched
 42 off at the end. When in operation, the boiler combusts biomass fuel in order to generate heat in the heat
 43 exchanger and consequently supply heat to the building. This combustion process causes soot accumulation
 44 in the heat exchange chamber, a process known as fouling, which degrades the boiler efficiency with time.
 45 During the transient when the boiler is switched on, a lag in the time taken to reach the building set point is
 46 witnessed with degradation of boiler efficiency. Discomfort can thus be seen as a function of the additional
 47 time taken to reach a temperature set point due to the degradation of the boiler efficiency, which otherwise
 48 operates properly. [17] has also made use of this notion to quantify occupant comfort.

49 Consider Figure 1, where T_z is the zone temperature (namely the temperature in the building). When
 50 the boiler efficiency η is lower than η_{max} , the zone temperature takes a longer time to reach the lower bound
 51 of the comfort region δ . This introduces discomfort during the switching ON phase of the boiler. This
 52 discomfort is captured in the form of a time delay expressed as the difference between the time taken for
 53 the zone temperature to reach the comfort region with the current η level and the time taken to reach the
 comfort level when the boiler operates using the maximum efficiency η_{max} ($t_\eta - t_{\eta_{max}}$). Thus, to properly

Figure 1: The effect of boiler degradation on the zone temperature and the introduced discomfort, during the transient operation of a boiler as it transitions from the OFF to the ON state. Here $T_z(t_0)$ is the initial temperature, T_{SP} is the zone temperature set-point, δ represents the acceptable comfort region and the discomfort region is $t_\eta - t_{\eta_{max}}$.

capture the effect of discomfort due to boiler degradation the following rule is applied:

Account for discomfort only when:

$$T_z < T_{SP} - \frac{\delta}{2} \text{ and } b_{on} = 1, \quad (1)$$

where T_z represents the zone temperature, T_{SP} is the required temperature set point, δ represents the width of the considered comfort region, and $b_{on} = 1$ represents the boiler in the ON state.

In order to capture the total time taken to reach the temperature set point within the zone and to apply the defined rule to compute the associated discomfort, we consider a thermal model representing the zone dynamics. Whilst this model accounts for the intra-day temperature dynamics, the discomfort metric is a daily value that can be employed in the cost function alongside operational and maintenance costs (as discussed later). In this work, the thermal model being used is a first-order model that is given by

$$C_r \frac{d(T_z)}{dt} = \frac{T_{out} - T_z}{R_{ow}} + \eta b_{on} P_{in} + P_{occ} + P_{rad}. \quad (2)$$

Here T_z is the zone temperature, T_{out} is the outside air temperature, P_{in} is the biomass boiler input power with b_{on} representing the when the boiler is on, P_{rad} is the heat gained from solar radiation, P_{occ} is the heat gained due to occupants, C_r is the zone capacitance, R_{ow} is the thermal resistance of the zone envelope, and $\eta \in [0, 1]$ is the daily boiler efficiency, which is the dual of the boiler degradation $(1 - \eta)$. The values of the parameters C_r and R_{ow} are estimated from data using maximum likelihood [18, 19] or Kalman filtering [20].

To compute the total time to reach the temperature set point (T_{SP}) following an OFF/ON boiler transition, (2) is solved analytically, considering the initial time to be t_0 and $b_{on} = 1$, (as per (1)):

$$T_z(t_\eta) = \exp\left(\frac{-t_\eta}{C_r R_{ow}}\right) \left(T_z(t_0) + \eta P_{in} R_{ow} \left[\exp\left(\frac{t_\eta}{C_r R_{ow}}\right) - \exp\left(\frac{t_0}{C_r R_{ow}}\right) \right] + \int_{t_0}^{t_\eta} \exp\left(\frac{\tau}{C_r R_{ow}}\right) \frac{T_{out}(\tau)}{C_r R_{ow}} d\tau + \int_{t_0}^{t_\eta} \exp\left(\frac{\tau}{C_r R_{ow}}\right) \frac{P_{occ}(\tau)}{C_r} d\tau + \int_{t_0}^{t_\eta} \exp\left(\frac{\tau}{C_r R_{ow}}\right) \frac{P_{rad}(\tau)}{C_r} d\tau \right), \quad (3)$$

where t_η is the final time step and indicates the time at which the lower comfort temperature value is reached ($T_z(t_\eta) = T_{SP} - \frac{\delta}{2}$) and where we assume next for simplicity that $t_0 = 0$. In order to reason about longer-term device degradation and the corresponding maintenance actions, we intend to map the continuous temperature dynamics into daily discrete discomfort values that quantify the effect of boiler degradation on thermal comfort. To perform such a mapping, the following choices and observations are made:

1. Define the daily time steps as $n = \{1, \dots, N\}$, with N being the final time step.
2. $(T_{SP} - \frac{\delta}{2})$ represents the required minimal temperature for comfort (cf. (1)).
3. C_r, R_{ow} are fixed and given parameters based on the characteristics of the zone heated by the boiler.
4. We represent the term P_{in} by a new variable P_{mn} , which is fixed during a day. P_{mn} represents the mean of the total input power P_{in} supplied to the boiler over the course of the day and captures the switching on and off of the biomass boiler during the day as a simple daily variable.
5. $T_z(t_0) = T_{out}[n]$ and $P_{occ} = P_{rad} = 0$, which captures a worst-case discomfort due to the boiler degradation during the heating season. Here $T_{out}[n]$ represents the worst case equilibrium temperature in the zone reached during the interval when the boiler is switched off.

6. We have access to the daily demanded output power $Q_{out}[n]$ and input power $Q_{in}[n]$ from which $\eta[n]$ is computed as,

$$\eta[n] = \frac{Q_{out}[n]}{Q_{in}[n]}. \quad (4)$$

7. As the efficiency, $\eta \rightarrow 0$ (degradation level is too high) and $T_{out} = T_z, \frac{dT_z}{dt} \rightarrow 0$, hence the boiler will be supplying negligible heat gain to the room and T_z will not reach the required minimal temperature for comfort $(T_{SP} - \frac{\delta}{2})$. This leads to a maximum discomfort, which is denoted with value $discTime_{max}$.

Solving (3) for $t_{\eta[n]}$ (for each daily time step n), the resulting total time required to reach comfort zone is then given by

$$t_{\eta[n]} = C_r R_{ow} \ln \left[\frac{-\eta[n] P_{mn} R_{ow}}{(T_{SP} - \frac{\delta}{2}) - (\eta[n] P_{mn} R_{ow} + T_{out}[n])} \right]. \quad (5)$$

2.1. Computation of discomfort time

In order to capture the daily discomfort (for day n), the continuous-time thermal model described above is employed to predict the daily temperature evolution, and the total discomfort time ($discTime$) is set as the difference between the time taken to reach set point comfort zone when operating at maximum efficiency ($t_{\eta[n]} = t_{\eta_{max}}$) and the time taken to reach the set point with the efficiency level at day n ($t_{\eta[n]}$). More precisely, the value of $t_{\eta_{max}}$ is computed by using (5) with $\eta[n] = \eta_{max}$, while the value of $t_{\eta[n]}$ is computed by again applying (5) with the current $\eta[n]$. The quantity $discTime$ is then:

$$discTime[n] = \begin{cases} \min\{t_{\eta[n]} - t_{\eta_{max}}, discTime_{max}\} & \eta[n] > \frac{(T_{SP} - \frac{\delta}{2}) - T_{out}}{P_{mn} R_{ow}} \\ discTime_{max}, & \text{Otherwise.} \end{cases} \quad (6)$$

The condition $\eta[n] > \frac{(T_{SP} - \frac{\delta}{2}) - T_{out}}{P_{mn} R_{ow}}$ is introduced to capture discomfort both when the boiler is able to reach the required comfort level and when it is not. When the comfort level is never reached, this condition is not met and the maximum possible discomfort time, $discTime_{max}$, which is set to 12 hours, is assigned.

Remark 1. Note that when the zone temperature exhibits oscillatory dynamics due to either sufficiently high degradation levels in the boiler (equivalently, sufficiently low boiler efficiency) or when the boiler has been improperly sized and does not supply enough heat to the zone, the zone dynamics do not converge to the set-point as shown in Figure 1. Consequently, the discomfort computation reasoning would need to be further elaborated using the same line of reasoning. In this case, the boiler is assumed to be properly sized and the constant $discTime_{max}$ is used to give an adequate discomfort penalty when the comfort region is never reached.

3. Synthesis of the optimal maintenance strategy

We first formalize the fouling process as a dynamic system and select a daily time step such that (i) the transient discomfort metric can be captured and (ii) the overall longer-term contributions of the heating demand can be embedded. We will represent the daily time steps as $n = \{1, \dots, N\}$, with N representing the final time horizon. We have access to the daily demanded output power $Q_{out}[n]$ and input power $Q_{in}[n]$ from which we also gain access to the aggregated daily biomass boiler efficiency level $\eta[n]$ (cf. (4)).

The possible states are $(Q_{out}, \eta) \in \mathbb{R}^2$, and we succinctly represent states as x . The set of all maintenance actions is $u[n] \in U, U = \{0, 1, 2\}$, where:

$$U = \begin{cases} 0 & \text{No Action,} \\ 1 & \text{Clean,} \\ 2 & \text{Replace.} \end{cases} \quad (7)$$

115 As suggested in [11], the following dynamics for Q_{out} ,

$$Q_{out}[n+1] = \gamma Q_{out}[n] + (1-\gamma)h[n]r[n], \quad (8)$$

where $h[n]$ is a boolean function representing the heating season,

$$h[n] = \begin{cases} 1 & \text{Heating season,} \\ 0 & \text{Otherwise,} \end{cases}$$

116 and $r[n]$ captures the long-term trend of Q_{out} ,

$$r[n] = \beta_0 + \beta_1 \cos\left(\frac{2\pi n}{365}\right) + \beta_2 \sin\left(\frac{2\pi n}{365}\right) + \beta_3 \cos\left(\frac{4\pi n}{365}\right) + \beta_4 \sin\left(\frac{4\pi n}{365}\right), \quad (9)$$

117 where $\beta_i, i = \{0, \dots, 4\}$ are parameters: this will be further discussed in Subsection 4.1.

118 The efficiency model η is set up as

$$\eta[n+1] = \begin{cases} \eta[n] + \alpha Q_{out}[n] & u[n] = 0, \\ g(\eta[n]) & u[n] = 1, \\ \eta_{max} & u[n] = 2. \end{cases} \quad (10)$$

119 The model depends on the control action performed ($u[n]$). When no cleaning is performed ($u[n] = 0$),
 120 the efficiency degrades based on the value of $Q_{out}[n]$ and on the previous $\eta[n]$. In this case, the parameter
 121 ($\alpha < 0$), related to boiler fouling, is estimated from sampled boiler data, representing Q_{out} and η , by
 122 applying the standard `lsq` Matlab function. If on the other hand cleaning ($u[n] = 1$) is performed, $\eta[n]$
 123 is updated based on a given function $g(\eta[n])$, which represents the chosen cleaning model. Computation of
 124 $g(\eta[n])$ will be further discussed in Subsection 4.1. Finally, when a replacement occurs ($u[n] = 2$), the
 125 efficiency level is restored to η_{max} .

126 During each period n , the associated costs are a function of the dynamical system and action performed
 127 and is expressed as

$$\begin{aligned} C(x[n], u[n]) &= C^{op}(x[n]) + C^{maint}(u[n]) + C^{disc}(x[n]) \\ &= p_{in} \frac{Q_{out}[n]}{\eta[n]} + p_{maint}u[n] + p_{disc}discTime[n]. \end{aligned} \quad (11)$$

128 The function is composed of three separate costs, as follows:

- 129 1. **Operational costs.** This is the cost associated with the working of the boiler, with p_{in} representing
 130 the monetary fuel costs. The higher the demanded output power and fuel costs, and the lower the
 131 efficiency, the higher the operational costs.
- 132 2. **Maintenance costs.** This is due to either the cleaning or to the replacement of the boiler with

$$p_{maint} = \begin{cases} p_{clean} & u[n] = 1, \\ p_{replace} & u[n] = 2, \\ 0 & \text{Otherwise.} \end{cases} \quad (12)$$

133 Here, p_{clean} and $p_{replace}$ represent the constant monetary costs of cleaning and replacement, respec-
 134 tively.

- 135 3. **Discomfort costs.** This cost is due to degraded thermal regulation due to boiler degradation. It is
 136 a function of the monetary discomfort cost, p_{disc} , and of $discTime[n]$, which is computed using (6).

We are interested in the optimal maintenance strategy that minimizes the total costs over a time interval, $n = \{1, \dots, N\}$. The optimal maintenance policy is obtained by computing the decision rule

$\pi[n] : (Q_{out}, \eta) \rightarrow U$ for all $n = \{1, \dots, N-1\}$, such that the total cost

$$\sum_{n=1}^N C(x[n], u[n]) \quad (13)$$

is minimised, subject to the state evolution model (representing the dynamics of the system) $x[n+1] = f(x[n], u[n])$, and to the control action $u[n] = \pi[n](x[n])$, where $\pi[n]$ is the policy. This can be solved by applying Dynamic Programming (DP) [21, 22]. The DP algorithm starts from the final time horizon N and backward recursively computes value functions V , which are minimized during each time step,

$$V[n](x[n]) = \min_{u[n] \in U} C(x[n], u[n]) + V[n+1](x[n+1]), \quad (14)$$

The optimal policy $\pi[n]$ is obtained as a look-up table (LUT) expressing the optimal input action to perform for a given Q_{out} and η pair. The employed algorithms are further elaborated in Subsection 4.3.

4. Case Study

We consider data from a real building, involving the heating of a school in Spain by a properly-sized biomass boiler [23]. The school is only operated on weekdays and the heating system is switched on from 08:00 to 15:00, between the first week of November and the last week of February (a total of 14 weeks), with the exception of the last week in December and the first week in January when the building is closed. The biomass boiler input ($P_{in,d}$)¹ and output power ($P_{out,d}$) have been logged for one year, with a 15-minute sampling time. The daily trend of power demand by the boiler, the daily supplied power, and the the mean daily boiler input power are computed using the quantities

$$Q_{out,d}[n] = \sum_{k=(n-1)q+1}^{nq} P_{out,d}[k], \quad Q_{in,d}[n] = \sum_{k=(n-1)q+1}^{nq} P_{in,d}[k], \quad P_{mn,d}[n] = \sum_{k=(n-1)q+1}^{nq} \frac{P_{in,d}[k]}{q}. \quad (15)$$

Here $n = \{1, \dots, 365\}$ represents the daily time steps, k is an index representing the aggregation of the 15-minute sampled data per day, and $q = 4 \times 24$ represents the total number of records per day. The boiler efficiency is defined as the ratio between the output power demand and the input power, and it can be derived from $Q_{out,d}$ and $Q_{in,d}$ as

$$\eta_d[n] = \frac{Q_{out,d}[n]}{Q_{in,d}[n]}. \quad (16)$$

Daily weather measurements of the outside air temperature $T_{out,d}[n]$ have also been recorded. The zone capacitance C_r and R_{ow} are given having a value of $54.56 J/K$ and $0.023 K/W$, while the required set-point T_{SP} and comfort region δ are given as $21^\circ C$ and $\pm 1^\circ C$, respectively.

We are interested in optimally scheduling the maintenance of the biomass boiler using the framework presented in Section 3, so that maximal cost savings are attained. Costs relate to energy usage in regular (possibly degraded) daily operation of the boiler, to device maintenance actions, and to occupant discomfort due to boiler degradation within the heating zone. We have selected a prediction horizon of $N = 5 \times 365$ (5 years) and considered daily contributions to the overall costs. The case study and all algorithms are implemented in Matlab R2016b.

4.1. Model of boiler degradation

The dynamics for the underlying degradation model are based on two variables representing the evolution of demanded output power Q_{out} and efficiency η respectively (cf. Sec 3). The models assume that the zones are not used during the weekends, and are built based on one year of training data obtained from the Spanish school data set.

¹Throughout this paper we denote data with variables of the form x_d , while models variables as x .

169 *Model for output power demand.* We make use of (8) and create a classifier $h[n]$ that for a given n , a value
 170 of one is assigned during the heating season and zero otherwise. Next, we construct the long-term trend $r[n]$
 171 by regressing Spanish school data of $Q_{out,d}$ corresponding to when the heating demand is positive, by means
 172 of use of frequency-domain linear regression [24]. This results in (9) with β_i , $i = \{0, \dots, 4\}$ correspond to
 173 the values in Table 1 and are obtained by fitting the model using the `lsconv` Matlab function. The resulting
 174 parameters are in the order of 10^5 due to the magnitude of $Q_{out,d}$ values (10^4) which the function is trying
 175 to model. The resulting fit has a standard deviation equivalent to 17.01% of the mean.

Table 1: Values of regressed parameters β_i

Parameter	β_0	β_1	β_2	β_3	β_4
Value ($\times 10^5$)	-1.079	-0.581	1.664	0.392	0.291

176 The parameter $\gamma \in [0, 1]$ is estimated by minimizing the following objective function, namely

$$\gamma = \arg \min_{\gamma} \sum_{d=2}^{365} (Q_{out,d}[n] - \gamma Q_{out,d}[n-1] - (1-\gamma)h[n]r[n])^2, \quad (17)$$

177 over the whole training data set (365 days). The resulting value is $\gamma = 3.125 \times 10^{-10}$, which is due to
 178 the overall mean difference between $Q_{out,d}$ and $r[n]$ and leads to a small contribution of the auto-regressive
 179 term.

180 *Model for efficiency.* The efficiency model η is set up using (10). In our case when $u[n] = 0$, using η_d and
 181 $Q_{out,d}$ we get $\alpha = -1.074 \times 10^{-7} \text{ kWh}^{-1}$. The small order of magnitude of α (10^{-7}) is a direct consequence
 182 of the large magnitude of Q_{out} which is in the order of 10^4 . This model corresponds to a 13% efficiency drop
 183 over one heating season.

If cleaning $u[n] = 1$ is performed, $\eta[n]$ is updated based on a given function $g(\eta[n])$ as in Figure 2. The trend is computed by fitting the curve,

$$g(\eta[n]) = \begin{cases} a_1 \exp\left(-\left(\frac{\eta[n]-b_1}{c_1}\right)^2\right) + a_2 \exp\left(-\left(\frac{\eta[n]-b_2}{c_2}\right)^2\right) & \eta[n] < \eta_{max} \\ \eta_{max} & \text{Otherwise,} \end{cases} \quad (18)$$

184 to training data obtained from the rule that the effect of cleaning varies between 7 and 15% depending on
 185 the current efficiency level and up to the maximum efficiency level (η_{max}) [25]. Here, $a_1 = 0.654$, $b_1 =$
 186 0.681 , $c_1 = 0.428$, $a_2 = 1.402$, $b_2 = 1.723$ and $c_2 = 0.661$. Figure 2 shows that for an initial $\eta[n] \geq$
 187 0.5 , cleaning results in an approximate improvement of 15% ($\eta[n+1] \approx 1.15\eta[n]$), whilst for an initial
 188 $0.1 < \eta[n] < 0.5$, cleaning results in an approximate 7% of overall improvement ($\eta[n+1] \approx 1.07\eta[n]$). For
 189 $\eta[n] < 0.1$, the cleaning effect saturates to 0.08.

190 When a total replacement occurs ($u[n] = 2$), the efficiency level is restored to $\eta_{max} = 0.8$.

191 4.2. Regression functions for prediction of the time spent in discomfort

192 We are interested in optimally scheduling maintenance based on the dynamic fouling model, composed
 193 using the states (Q_{out}, η) , and the total costs (operational, maintenance and discomfort costs). Using the
 194 state-space models we obtain the operational and maintenance costs directly (cf. (11)). However, to compute
 195 the discomfort costs, we need to predict *discTime* over the required time horizon using (6). *discTime* is
 196 a function of the dynamic variables η , T_{out} and P_{mn} and the fixed variables C_r, R_{ow}, δ and T_{SP} (these are
 197 given). Consequently, to predict *discTime* using the fouling model, we need to construct models which relate
 198 the Q_{out} to T_{out} and Q_{out} to P_{mn} . The Spanish data set contains the following variables, $Q_{out,d}, Q_{in,d}, T_{out,d}$
 199 and $P_{mn,d}$, which allows us to construct the required regression functions to relate Q_{out} to T_{out} and Q_{out}
 200 to P_{mn} .

Figure 2: The imperfect cleaning model $g(\eta[n])$, incorporating the effect that for high initial values of η the effect of cleaning is large, while for low initial values of η the effect of cleaning is low. The value of η following cleaning saturates at a maximum value of $\eta = 0.8$ and at a minimum value of $\eta_{min} = 0.08$.

Regression models relating Q_{out} and T_{out} . Two candidate regression models that relate Q_{out} and T_{out} are found by considering the recorded Spanish weather data.

- **Candidate 1:** The linear model

$$T_{out}[n] = \beta \frac{Q_{out}[n] - \mu}{\sigma} + \zeta, \quad (19)$$

- **Candidate 2:** - The exponential model

$$T_{out}[n] = \frac{e^{\gamma \frac{Q_{out}[n] - \mu}{\sigma}} - \alpha}{\psi}. \quad (20)$$

Here, μ and σ are the mean and standard deviation of $Q_{out,d}$. The exponential model is considered in this section due to the exponential relationship between Q_{out} and T_{out} obtained by considering the linear relationship between Q_{out} and P_{out} and then the exponential relationship between P_{out} and T_{out} as can be seen from (3). For both models, the unknown parameters can be estimated by solving,

$$\min_{\theta} \sum_{l=1}^L (v[n] - w[n, \theta])^2. \quad (21)$$

Here θ are the parameters to be estimated, l is an index representing the training data having a total length $L = 365$ and $v[n] = T_{out,d}[n]$. For the case of the linear model $w[n, \theta] = \beta \frac{Q_{out}[n] - \mu}{\sigma} + \zeta$ with $\theta = [\beta, \zeta]^T$, while for the case of the exponential model $w[n, \theta] = \frac{e^{\gamma \frac{Q_{out,d}[n] - \mu}{\sigma}} - \alpha}{\psi}$ with $\theta = [\gamma, \alpha, \psi]^T$ and with $\mu = 9.84 \times 10^3$, $\sigma = 5.78 \times 10^3$ representing the mean and standard deviation of $Q_{out,d}$ respectively. The resulting parameter values from this minimisation are $\beta = -0.3743$ and $\zeta = 1.847$ for the linear model, $\gamma = -0.4932$, $\alpha = 0$, $\psi = 0.4840$ for the exponential model. The resulting fit for both candidates is shown in Figure 3.

The exponential model is chosen as the best model to compute the value of T_{out} from Q_{out} as it achieved the lowest RMSE (the linear model achieved an RMSE value of 2.378, whereas the exponential model has an RMSE value of 2.278).

Regression models relating Q_{out} and P_{mn} . A similar approach is carried out to regress the relationship between Q_{out} and P_{mn} such that predictions of the total time in discomfort can be made. In this case, as

intuitive only a linear model is considered, and the recorded data for the mean input power during a day, $P_{mn,d}$ is used (cf. (15)). The resulting model is given by

$$P_{mn}[n] = \beta_1 Q_{out}[n] + \zeta_1 \quad (22)$$

where $\beta_1 = 4.262 \times 10^{-2}$ and $\zeta_1 = 210$. The parameters are estimated once again using (21) with $\theta = (\beta_1, \zeta_1)^T$, $v[n] = P_{mn,d}[n]$ and $w[n, \theta] = \beta_1 Q_{out,d}[n] + \zeta_1$. The resulting fit is shown in Figure 4. The model fitness has a RMSE value of 99.6.

4.3. Solution of the dynamic programming problem

Using the defined state evolution models and cost functions the optimal maintenance problem is solved by employing the DP framework. We consider two modalities for performing the soot cleaning actions: on-load and off-load [26, 27]. The biomass boilers can be cleaned while it is running by being fitted with retractable soot blowers which perform cleaning (on-load). Alternatively and conventionally, soot cleaning can be performed when the boiler is disconnected (off-load).

Two algorithms are proposed each representing a different type of cleaning modality (on-load and off-load cleaning). Algorithm 1 considers the off-load scenario incorporating a total of one time delay to perform a cleaning action, while Algorithm 2 assumes that the maintenance actions are carried out instantaneously, which is the case when on-load cleaning is carried out.

Algorithm 1: Dynamic Programming Algorithm for off-load cleaning

input : model (Q_{out}, η)
output: V function for given parameters, $\pi(x[n])$ decision rule for each given state

- 1 Start at final time step N
- 2 $V[N](x[N]) \leftarrow \infty$
- 3 **forall** the $n = N - 1 : 1$ **do**
- 4 **if** $u = 0$ **then**
- 5 $V[n](x[n]) = \{C^{op}(x[n]) + C^{disc}(x[n]) + V_{n+1}(f(x[n], 0))\}$
- 6 **else**
- 7 $V[n](x[n]) = \min_{u[n] \in \{1, 2\}} \{C(x[n], u[n]) + C((0, 0), u[n]) + V_{n+1}(f(x[n], u[n]))\}$
- 8 $\pi[n](x[n]) = \arg \min_{u[n] \in U} \{C(x[n], u[n]) + V_{n+1}(f(x[n], u[n]))\}$

For both algorithms, one must discretise the state space over the selected minimum and maximum bounds ($[\eta^{min} = 0.03, \eta^{max} = 0.8]$ and $[Q_{out}^{max} = 2.5 \times 10^4, Q_{out}^{min} = 0]$). The value function for each of the

Figure 3: Resulting model fit between Q_{out} and T_{out} . The exponential function is seen to have a better fit to the data.

Figure 4: Resulting model fit between Q_{out} and P_{mn} .

Algorithm 2: Dynamic Programming Algorithm for on-load cleaning

input : model (Q_{out}, η)
output: V function for given parameters, $\pi(x[n])$ decision rule for each given state

- 1 Start at final time step N
- 2 $V[N](x[N]) \leftarrow \infty$
- 3 **forall the** $n = N - 1 : 1$ **do**
- 4 $V[n](x[n]) = \min_{u[n] \in U} \{C(x[n], u[n]) + V_{n+1}(f(x[n], u[n]))\}$
- 5 $\pi[n](x[n]) = \arg \min_{u[n] \in U} \{C(x[n], u[n]) + V_{n+1}(f(x[n], u[n]))\}$

discretised states is then computed at each time step, recursively (cf. (14)). In the case of off-load cleaning one needs to incorporate the effect that maintenance actions take up to one day to be carried out. This is introduced as an additional cost penalty into the value function computation step corresponding to a day where $Q_{out} = 0$ since the boiler is not running (cf Algorithm 1 Line 7).

5. Case study: results

We synthetise optimal maintenance strategies, using the developed algorithm for both on-load and off-load cleaning, with a prediction time horizon considered set to $N = 5$ years. First, we consider two experiments to show the effect of discomfort monetisation on the resulting policy. For each experiment, we use the following prices (i) $p_{in} = \text{€}0.27/\text{kg}$ ² (ii) $p_{clean} = \text{€}108.90$, $p_{replace} = \text{€}5000$ ³ and (iii) $p_{disc} = \text{€}100/\text{day}$ [23]. In all cases, we encode the resulting control actions as follows - Dark Blue: Replace boiler; Light Blue: Clean Boiler; White: No Action.

Experiment 1: Presence vs absence of discomfort.

Figure 5 shows the resulting look-up tables (LUT) for the optimal control actions as a function of η values. The LUT are generated using Algorithm 1.

Remark 2. *The resulting optimal maintenance strategy can be seen to be qualitatively periodic within each heating season due to the periodic trend of the demanded output power (cf. (9)). However, this periodicity is only approximate, due to the differences in the initial η and Q_{out} at the beginning of each heating season.*

In order to further clarify the effect of incorporating discomfort monetisation zoomed up versions of Figure 5 showing the resulting LUT for the heating season in 2014 and 2015 is presented. From Figure 6(a),

²<http://www.avebiom.org/es/noticias/News/show/precios-del-pellet-en-espana-653>

³<http://www.tucalderabarata.es/reparacion-de-calderas/>

Figure 5: The resulting LUT for the optimal control actions when (a) discomfort costs are included and (b) not included. The control actions are colour coded using - Dark Blue: Replace boiler; Light Blue: Clean Boiler; White: No Action.

it can be seen that when we consider discomfort in the optimal policy computation, cleaning actions are only performed on weekends when it is expected that the boiler is operated throughout the rest of the week. This minimises the effect of discomfort experienced had boiler maintenance been performed when the building is in use. For weeks 2 to 7 and weeks 14 and 15, when $0.11 < \eta < 0.18$ replacement is carried out during weekends. For weeks 10 to 13, this replacement is performed when $0.13 < \eta < 0.19$. This is due to the higher expected Q_{out} . When $\eta \leq 0.13$ for weeks 10 to 13 and $\eta \leq 0.11$ for the rest of the weeks excluding week 8, the cost of operation is much larger then the cost of discomfort and thus maintenance actions are performed on weekdays. On the other hand, from Figure 6(b) we deduce that when discomfort is not considered, cleaning actions are performed both on weekdays and weekends for all weeks excluding week 8. No maintenance actions are performed on Saturday due to the one step ahead prediction of a no power demand Q_{out} since the boiler is switched off on Sunday. No maintenance actions are performed in week 8 for both scenarios as the boiler is switched off throughout the whole week.

Figure 6: Optimal Maintenance strategy that (a) presence vs (b) absence of discomfort costs over one heating season (from Monday of the first week of November 2014 up to Sunday of the last week of February 2015). The control actions are colour coded using - Dark Blue: Replace boiler; Light Blue: Clean Boiler; White: No Action.

For these two scenarios, we perform a set of 10^3 simulation runs where we obtain an initial efficiency

level by sampling a uniform distribution between the range $[0.03, 0.8]$ and with Q_{out} fixed to 1.183×10^4 (corresponds to initial value found in Spanish school data set), are performed. For each run ((i) using LUT generated using $p_{disc} = \text{€}100/\text{day}$; (ii) using LUT generated using $p_{disc} = \text{€}0/\text{day}$), we further compute the total discomfort cost incurred when the optimal maintenance strategy is employed and the total reduction in discomfort cost achieved by the DP that considers the discomfort costs. The resulting total reduction in discomfort is shown in Figure 7. It can be seen that the total reduction in discomfort is a function of the initial efficiency level, η . For $0.11 < \eta < 0.14$, we achieve higher discomfort savings, due to extra discomfort penalty associated with not replacing the boiler. We obtain no discomfort savings for the ranges $\eta < 0.09$ and $0.76 < \eta$, as the same control actions are performed in both scenarios (cf. Figure 6). An overall average savings of 15.76% is also deduced.

Figure 7: The resulting reduction in total discomfort costs for different initial η values. When $0.11 < \eta < 0.14$, we achieve higher discomfort savings are achieved due to extra discomfort penalty associated with not replacing the boiler. For $\eta < 0.09$ and $0.76 < \eta$, the same control actions are performed in both scenarios resulting in no discomfort savings.

Experiment 2: On-load cleaning (instantaneous) vs Off-load cleaning (1 day delay).

A comparison is made between the two algorithms (Algorithm 2 and 1). Figure 8(a) and 8(b) depict zoomed up versions of the resulting LUT for 2015-2016 heating season when using Algorithm 1 and 2 respectively. From Figure 8(a), we deduce that when employing on-load cleaning, all cleaning actions are carried out during weekdays. An extra cleaning action is introduced for $\eta \leq 0.14$ and is performed on Saturdays. In this case, the cost of discomfort has minimal effect on when to perform maintenance actions. On the other hand, from Figure 8(b) it is clear that the cost of discomfort directly limits when maintenance actions are performed. All cleaning actions are performed during weekends. This is desirable as performing cleaning during weekdays would result in discomfort as the heating zone is in use and would need to be taken off-load.

5.1. Energy savings

We perform a comparison between the developed algorithm and standard cleaning policies carried out in the industrial practice, in order to estimate the total energy savings gained by the proposed algorithms, using a set of 10^3 simulations. In all instances, we obtain the initial degradation level from sampling a uniform distribution between the range $[0.03, 0.8]$ and Q_{out} is fixed to 1.183×10^4 (corresponds to initial value found in Spanish school data set). We use a time horizon of $N = 5$ years and do not include the discomfort and the control action equivalent to a boiler replacement in order to be able to make a direct comparison with standard practices where replacement actions are only performed after a longer time horizon (typically $N = 15$ years). A condition-based function is extracted from the generated optimal policies

$$u[n] = \begin{cases} \text{Clean} & 0.76 \leq \eta[n], \\ \text{No Action} & \text{Otherwise.} \end{cases} \quad (23)$$

Figure 8: The optimal maintenance strategies obtained when employing (a) Algorithm 1 and (b) Algorithm 2. In both figures, the control actions are colour coded using - Dark Blue: Replace boiler; Light Blue: Clean Boiler; White: No Action.

Here, $\eta[n] = 0.76$ is chosen as it is the maximum value beyond which no maintenance actions are performed as deduced from the resulting LUTs (Figure 6).

Table 2: Energy Savings Comparison

Strategy	Total Costs	Maintenance Actions	Savings compared to Off-load Cleaning DP
Off-load cleaning DP	2.175×10^6	16	0%
On-load cleaning DP	2.171×10^6	15	0.15%
Condition based	2.191×10^6	14	0.75 %
Weekly cleaning during heating season	3.105×10^6	70	42.79%
Six Month cleaning	2.455×10^6	9	12.89 %
Annual cleaning	3.474×10^6	5	59.73%

We tabulate the results obtained from this analysis in Table 2. From the outcomes, we confirm that the most effective energy policy is obtained when the DP algorithm is employed, with comparable energy savings between the on-load and off-load cleaning algorithms. The off-load strategy (introduces an additional cost during the off-load period which is only due to discomfort and the maintenance action being performed as the boiler is not operational) compared to the on-load strategy requires that an additional maintenance action is performed. This additional maintenance strategy keeps the boiler operating at higher efficiency levels and since the cost of maintenance and discomfort are much lower than the cost of degraded boiler operation, there is a slight reduction in the overall costs due to operation ($C^{op}(x[n])$) which leads to more energy savings being gained by the off-load strategy.

6. Conclusions

The paper presents a methodology for quantifying discomfort due to boiler degradation, and a corresponding optimisation algorithm based on dynamic programming algorithm that schedules a strategy for optimal boiler maintenance. The work encompasses dynamics at two different time scales: (i) daily dynamics

for the prediction of discomfort, and (ii) long-term dynamics that are key for maintenance strategies. The resulting strategy allows for different actions based on the cleaning technique employed by contractors (partial cleaning vs replacement). This results in more realistic predictive maintenance strategies, with effective cost and energy savings. The presented framework can be further enhanced with a dynamic discomfort monetisation function, and by incorporating predictive models representing solar heat gain and building occupancy. The dynamic programming algorithm may also be enriched by incorporating time delays in the state evolution models to represent different time delays introduced by different cleaning and replacement maintenance methods.

Acknowledgements

This work has been funded by the European Commission in the Seventh Framework Programme project AMBI (Grant Agreement no. 324432). This work is in part supported by the Alan Turing Institute, London, UK and Malta's ENDEAVOUR Scholarships Scheme.

References

- [1] C. Böhringer, A. Löschel, U. Moslener, T. F. Rutherford, EU climate policy up to 2020: An economic impact assessment, *Energy Economics* 31 (2009) S295–S305.
- [2] N. S. Bentsen, M. W. Jack, C. Felby, B. J. Thorsen, Allocation of biomass resources for minimising energy system greenhouse gas emissions, *Energy* 69 (2014) 506–515.
- [3] D. Tonini, C. Vadenbo, T. F. Astrup, Priority of domestic biomass resources for energy: Importance of national environmental targets in a climate perspective, *Energy* 124 (2017) 295 – 309.
- [4] B. A. Qureshi, S. M. Zubair, Predicting the impact of heat exchanger fouling in power systems, *Energy* 107 (2016) 595 – 602.
- [5] L. Wang, J. Chu, J. Wu, Selection of optimum maintenance strategies based on a fuzzy analytic hierarchy process, *International Journal of Production Economics* 107 (1) (2007) 151–163.
- [6] V. Babishin, S. Taghipour, Optimal maintenance policy for multicomponent systems with periodic and opportunistic inspections and preventive replacements, *Applied Mathematical Modelling* 40 (2324) (2016) 10480 – 10505.
- [7] X. Zhou, L. Xi, J. Lee, Reliability-centered predictive maintenance scheduling for a continuously monitored system subject to degradation, *Reliability Engineering & System Safety* 92 (4) (2007) 530–534.
- [8] L. Pattanayak, S. P. K. Ayyagari, J. N. Sahu, Optimization of sootblowing frequency to improve boiler performance and reduce combustion pollution, *Clean Technologies and Environmental Policy* 17 (7) (2015) 1897–1906.
- [9] H. Zhao, F. Magoulès, A review on the prediction of building energy consumption, *Renewable and Sustainable Energy Reviews* 16 (6) (2012) 3586–3592.
- [10] J. Berka, K. Macek, Effective maintenance of stochastic systems via dynamic programming, *Proc. Technical Computing Prague 2011*, Prague: Czech Republic.
- [11] K. Macek, P. Endel, N. Cauchi, A. Abate, Long-term predictive maintenance: A study of optimal cleaning of biomass boilers, *Energy and Buildings* 150 (2017) 111 – 117.
- [12] R. Valancius, A. Jurelionis, V. Dorosevas, Method for cost-benefit analysis of improved indoor climate conditions and reduced energy consumption in office buildings, *Energies* 6 (9) (2013) 4591–4606.
- [13] M. M. Tehrani, Y. Beauregard, M. Rioux, J. P. Kenne, R. Ouellet, A predictive preference model for maintenance of a heating ventilating and air conditioning system, *IFAC-PapersOnLine* 48 (3) (2015) 130 – 135.
- [14] K. Nikhil, M. C. Kurian, Selection of optimum maintenance approach based on analytic hierarchy process (AHP), *International Journal of Engineering Development and Research* 4 (2016) 454–459.
- [15] H. Maula, V. Hongisto, L. Östman, A. Haapakangas, H. Koskela, J. Hyönä, The effect of slightly warm temperature on work performance and comfort in open-plan offices-a laboratory study, *Indoor air* 26 (2) (2016) 286–297.
- [16] W. Cui, G. Cao, J. H. Park, Q. Ouyang, Y. Zhu, Influence of indoor air temperature on human thermal comfort, motivation and performance, *Building and environment* 68 (2013) 114–122.
- [17] A. Aswani, N. Master, J. Taneja, A. Krioukov, D. Culler, C. Tomlin, Quantitative methods for comparing different hvac control schemes, in: *Performance Evaluation Methodologies and Tools (VALUETOOLS)*, 2012 6th International Conference on, IEEE, 2012, pp. 326–332.
- [18] M. Maasoumy, A. Sangiovanni-Vincentelli, Total and peak energy consumption minimization of building HVAC systems using model predictive control, *IEEE Design Test of Computers* 29 (4) (2012) 26–35.
- [19] P. Bacher, H. Madsen, Identifying Suitable Models for the Heat Dynamics of Buildings, *Energy and Buildings* 43 (7) (2011) 1511–1522.
- [20] S. Baldi, S. Yuan, P. Endel, O. Holub, Dual estimation: Constructing building energy models from data sampled at low rate, *Applied Energy* 169 (2016) 81–92.
- [21] D. P. Bertsekas, *Dynamic programming and optimal control*, Vol. 1, Athena Scientific Belmont, MA, 1995.

- [22] B. kugor, J. Deur, Dynamic programming-based optimisation of charging an electric vehicle fleet system represented by an aggregate battery model, *Energy* 92, Part 3 (2015) 456 – 465, sustainable Development of Energy, Water and Environment Systems.
- [23] M. Schmidt, M. V. Moreno, A. Schülke, K. Macek, K. Mařík, A. G. Pastor, M. Schmidt, M. V. Moreno, A. Schlke, K. Macek, K. Mak, A. G. Pastor, Optimizing legacy building operation: The evolution into data-driven predictive cyber-physical systems, *Energy and Buildings* 148 (2017) 257 – 279.
- [24] R. H. Shumway, D. S. Stoffer, *Time series analysis and its applications: with R examples*, Springer Science & Business Media, 2010.
- [25] T. Morley, What you need to know about biomass boiler servicing., Greenpower Technology Online resource, accessed December 2016.
- [26] A. Valero, C. Cortes, Ash fouling in coal-fired utility boilers. Monitoring and optimization of on-load cleaning, *Progress in energy and combustion science* 22 (2) (1996) 189–200.
- [27] A. Bianchini, F. Cento, L. Golfera, M. Pellegrini, C. Saccani, Performance analysis of different scrubber systems for removal of particulate emissions from a small size biomass boiler, *Biomass and Bioenergy* 92 (2016) 31 – 39.